

Ministry of Health  
District Health Office  
Public Health Laboratory, Haifa  
15 Haparsim St, P.O.B. 9526, Haifa 35055  
Tel: 04-8619803 Fax: 04-8510172



משרד הבריאות  
לשכת הבריאות המחוזית  
המעבדה לבריאות הציבור - חיפה  
רח' הפרסים 15, ת"ד 9526, חיפה 35055  
טל: 04-8619803 פקס: 04-8510172

## Certificate of Analysis Minerals Testing – Water

Certificate No.: 22-67-68-2017

<b>Address for results:</b>	
<b>Date of receiving:</b> 23/01/17	<b>Testing termination date:</b> 26/01/17
<b>FAX:</b>	<b>Phone:</b>
<b>Laboratory No.:</b> 67-68	<b>Sender No.:</b>
<b>Sample description:</b> Water sample tested for a LOTUS filter	

### Results

Parameters	Units	Result before filtration in LOTUS	Result after filtration in LOTUS
Lab. No.		67	68
Lead (Pb)	µg/L	8.6	5.4

**Comments:**

<b>Name of the tester:</b> Amal Hanna	<b>Signature:</b>
<b>Name of the authorizer:</b> Dr. E. Kalily	<b>Position:</b> Chem. Lab. Manager
<b>Signature:</b>	

**End of certificate**

**Laboratory seal**

לשכת הבריאות המחוזית  
 המעבדה לבריאות הציבור  
 ת.ד. 800 חיפה 31999  
 טל: 04-8619705 פקס: 04-8510172

The results refer only to the tested sample.

The Israel Authority for Accreditation is not responsible for the results performed by the laboratory, and the accreditation does not certify the tested sample.

It should be to refer to the whole certificate and it's forbidden to copy from it into other certificates.